


# Certificate of Compliance

Certificate Number 20070509-MH25274  
Report Reference MH25274,2006Dec11 and MH25274,2006Dec12  
Issue Date 2007 May 9

Page 1 of 1



**Issued to:** Petrotechnik Ltd.  
Olympus Close, Petrotechnik House  
Whitehouse Industrial Estate  
Inswich, Suffolk. IP1 5LN United Kingdom

*This is to certify that representative samples of*

## Underground Piping for Flammable Liquids

50/63, 63/75, 90/110 and 110/125 mm Diameter Integral Primary/Secondary, Normal Vent and Vapor Recovery Piping Systems and 50, 63, 90 and 110 mm diameter Normal Vent and Vapor Recovery Piping for Motor Vehicle, Concentrated, High Blend, Aviation and Marine Fuels.


*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

**Standard(s) for Safety:** UL971 and ULC/ORD-C971-2005 for Nonmetallic Underground Piping for Flammable Liquids

**Additional Information:**

The maximum pressure vacuum ratings; rated tightening torque; the statement: "Use Only OEM Fittings - Follow Installation Instructions", or equivalent; the statement: "Underground Use Only"; the date, of manufacture; the type of pipe systems": Integral Primary/Secondary (PS), "Normal Vent" and/or "Vapor Recovery," and the Flammable Liquid Group Rating;" Motor Vehicle Fuels", "Concentrated Fuels", "High Blend Fuels" and/or "Aviation and Marine Fuels" shall be marked on the piping.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

### Look for the UL Listing Mark on the product

Issued by:

A handwritten signature in black ink, appearing to read 'Timothy Crews'.

Timothy Crews/Staff Engineer  
Underwriters Laboratories Inc.

Reviewed by:

A handwritten signature in black ink, appearing to read 'Milan Dotlich'.

Milan Dotlich/Operations Manager  
Underwriters Laboratories Inc.